

Evaluation Of Electric Energy Losses In Ehor 33kv Distribution Line.

Ogedegbe Omozei Joshua, Enobakhare Golden, Ehigie Eghe.

(Department Of Electrical And Electronics Engineering, Ambrose Alli University, Ekpoma Edo State.)

Abstract:

Electrical energy losses are an inherent part of power distribution systems, representing energy that is generated but never reaches the end-user. Minimizing these losses is crucial for an efficient power supply. A key strategy involves managing reactive power to maintain a power factor as close to unity as possible, which provides significant economic benefits for all consumers. For distribution companies, reducing losses translates directly to increased revenue, as more supplied energy is billed and paid for, rather than being written off as debt from unbilled losses. This requires universal metering for accurate energy accountability. When customers receive a more reliable supply and are billed correctly, their payment compliance improves. This study analyzed the Ehor 33 kV distribution line to quantify energy losses using data from transmission and distribution companies. It identified the causes of losses and evaluated mitigation methods, including the use of capacitor banks to improve the power factor. The findings confirmed that while losses financially burden the distribution company (Benin Electricity Distribution Company Plc), they paradoxically increase the revenue of the Transmission Company of Nigeria.

Keyword: Energy losses, billing, Sag-conductors, distribution line,

Date of Submission: 08-11-2025

Date of Acceptance: 18-11-2025

I. Introduction

The three subsystems of a power system for electric energy are generation, transmission, and distribution. Transmission stations use high-voltage transmission lines to transport the electricity generated at the producing station to the distribution substations [1]. The distribution system serves as the link from the distribution substations to the consumer. Electricity has emerged as a significant issue that influences the motivation required for technology to advance and support the growth of contemporary society [2]. This has demonstrated the importance of energy supply for socioeconomic and industrial development, boosting output across all segments of the national economy, including business, industry, agriculture, and mining. Electric power distribution is an essential conduit between utilities and consumers., thus playing a very important role in the entire power network [3]. Transmission and Distribution losses in Nigeria are becoming very high, but that of distribution is higher [4]. Due to the physics involved with the many system components that make up any power system, distribution system losses are a fact of life. Due to a lack of data, techniques for estimating losses have mostly concentrated on examining system losses during specific peak demand periods [5].

Power losses in the form of copper losses, core losses, and auxiliary losses demonstrate that distribution transformers experience significant amounts of distribution losses. This is because no transformer is flawless, and the highest level of efficiency is only attained when copper losses are equal to iron losses [6]. Energy losses in networks differ from generation to transmission and distribution. As for the distribution network, the amount of energy losses when energy is supplied to the network may or not be accounted for as a result of the energy losses on the line. Electric utilities have long been interested in distribution system losses due to the loss of revenue from power and energy that are purchased or generated, as appropriate, but are not sold [7]. The need for a more precise understanding of when system losses occur and their quantity throughout various pricing periods grows as a result of today's environment of hourly energy markets distribution congestion charges. Distribution businesses have given increasing energy efficiency a high priority [8]. Electric resistance in distribution lines continuously wastes energy in the electric power system. About 7% of the total quantity of energy produced was lost, with 2% lost during transmission and 5% lost during distribution [9]. Except for the voltage level and power handling capabilities, transmission lines and distribution lines are identical. Limited amounts of power are transported across shorter distances through distribution lines (networks). The voltage drops in lines depend on the lines' resistance, reactance, cable length, and current drawn [10]. The larger the current drawn and the bigger the voltage drop are all related to the voltage and the amount of power handled, respectively.

For a given amount of power handled, the voltage level is inversely proportional to the current drawn [11]. The main purpose of distribution equipment is to move electricity efficiently and dependably from one place to another. High voltages are carried via conductors in the form of wires and cables suspended from towers and poles. This paper focuses mainly on all the energy meter readings in all the 11 kV feeders in injection stations

and 33 kV distribution substations on Ehor 33 kV line of Benin Electricity Distribution Company Plc, and energy meter readings on Ehor 132/33 kV feeder in Transmission Company of Nigeria Station, Irrua.

II. Reviewed Literature

Electric energy losses in a distribution network occur as a result of commercial and technical losses throughout the process of supplying electricity to consumers.

In [12] the authors, presented an experimental study on frictional energy losses to lengthen the life of hydraulic cylinders, and respectively lifetime of the hydraulic drive system. while the authors in [13] presented research work on the reduction of power losses in a distribution network system using model and simulation results which demonstrated that putting his ideas into practice results in a noticeable improvement in voltage profile and a decrease in active and reactive power losses.

The authors in [14] opined a research work on improvement in power losses using distribution, and generation in the analysis of costs associated with system losses. [15] presented and evaluated losses in the distribution system using data from the installed advanced metering infrastructure and geographical information system. A broad evaluation using elements like conductors, and insulators were used to determine the overall system losses evaluation.

Research on the cost that is associated with system losses and the adoption of a new technique using a calculation to drive the cost associated with power losses was proposed by the authors in [16]. Further-more, authors in [17] presented a traditional analysis estimate on employing widely established methods that significantly rely on assumptions and that only consider peak and average demands on key system components, energy losses are produced.

An artificial intelligence technology concept was put together to develop formal search methods for energy losses in [18]. Comparison of the losses that would have occurred if the loads on the transformer were evenly divided throughout the phases to the consumers and the losses that were calculated for the transformer's copper were presented by [19].

III. Research Methodology

The source of electricity supply to Transmission Company of Nigeria (TCN) Irrua 132/33 kV station is from Benin-city 330/132 kV Transmission Company of Nigeria station, situated at kilometre six (6) along Sapele Benin high way road Benin-City, Edo State. While, the transmission company of Nigeria (TCN) Irrua 132/33 kV station, which is one of the major sites of this project work is situated along Benin/Auchi highway road after Irrua specialist teaching hospital junction Irrua.

Transmission Company of Nigeria (TCN) Irrua 132/33 kV station is supplying electricity to 90% of Edo North, parts of Delta State (Agbor, Abavo, Akoko-Agbor, Umunede etc.), and some parts of Edo South (Ehor, Ugbiyaya, Uhi, Eguneki, Ugha, Isi, etc.). The company has two power transformers which are 60MVA and 30MVA. The 60 MVA transformer is called transformer (T1) with three outgoing feeders, which are Uzebba Feeder, Agenebode feeder and Ehor feeder, and each feeder has its circuit breaker. While the 30 MVA transformer is called transformer (T2) with two outgoing feeders which are Agbor and Ubiaja feeders with individual breakers.




Fig. 1. The line diagram of TCN Irrua 132/33 kV station.




Fig. 2. Line diagram of BEDC Ekpoma 33/11 kV Injection station.

Also, the Benin Electricity Distribution Company (BEDC) Ambrose Alli University 33/11 kV injection station (Figs. 3. – 4) is situated inside the Ambrose Alli University compound close to their power station. The injection station has one power transformer of 7.5 MVA and two outgoing feeders which are Iruekpen feeders, with individual meters mounted on the feeders. The Ehor 33 kV network is the main scope of this project work which has its source from the Ehor 33 kV feeder from Transmission Company of Nigeria (TCN) Irrua station and ends at the Watchtower headquarters along Benin/Auchi express road in Igieduma, Ehor community. The Ehor 33 kV network from Transmission Company of Nigeria (TCN) Irrua station is presently supplying electricity to BEDC Irrua specialist teaching hospital (ISTH) 33/11 kV station, BEDC Ekpoma 33/11 kV station, BEDC Ambrose Alli University 33/11 kV station and BEDC Watchtower 33/11 kV station. Benin Electricity Distribution Company (BEDC) Irrua specialist teaching hospital (ISTH) 33/11 kV station has one power transformer of 2.5 MVA. This power transformer supplies electricity to six (6) 11/0.415 kV stations, which are the clinical 300 kVA transformer, doctors quarter 300 kVA transformer, Ortibor 500 kVA transformer, labour ward 300 kVA transformer, Larsa fever 300 kVA transformer and bank PHB 100 kVA transformer. All the transformers are metered. The Benin Electricity Distribution Company (BEDC) Ekpoma injection 33/11 kV station is situated along Benin Auchi highway road before Irrua specialist teaching hospital (ISTH) in MOPOL junction Ekpoma. The station has two power transformers which are 15 MVA each. One of the 15 MVA transformers is called transformer (T_1) and the other transformer (T_2) i.e. ($T_1 = T_2$) = 15 MVA transformer (T_1) with three outgoing feeders, which are Irrua feeder, Opoji feeder and express Ekpoma feeder. While the transformer (T_2) with two outgoing feeders which are Ekpoma town and Ujemen dedicated feeders. All these feeders are metered with individual whole meters which record all energy consumption by consumers.

Ehor 33 kV distribution line is extended up to the Jehovah witnesses' headquarters in Igieduma, Uhoumode local government area. Along the distribution line, some communities have distribution stations of 33/0.415 kV which comprise Ugbiyaya, Ukpoli, Arosa, Okemun and Ehor Market. All the individual 33/0.415 kV substations are properly metered, which records all the monthly energy consumed in a kilowatt hour.




Fig. 3. The line diagram of BEDC Ambrose Alli University 33/11 kV injection station.

Data Collection

Data based on energy transmitted from the Transmission Company of Nigeria (TCN) Irrua station as the source of electricity supply to the Ehor 33 kV distribution line based on power transmitted is extracted from their log book and recorded for the period of October 2018 to September 2019. Also, data based on energy consumption in all the distribution injection stations and substations along the Ehor 33 kV line of Benin Electricity Distribution Company are taken from their meter reading card and log books as recorded on monthly basis, based on energy distributed by the company in the period of October 2018 to September 2019

Therefore,

$$TTEC = TPSR - TPVR \text{ in MWH} \quad 3.1$$

Where,

Total Present Reading = $TPSR$ in MWH

Total Pervious Reading = $TPVR$ in MWH

Total Transmitted Energy Consumed = $TTEC$ in MWH

For Benin Electricity Distribution Company:

Total Present Reading = $TPSR$ in MWH

Total Previous Reading = $TPVR$ in MWH

Total Distribution Energy Consumption = $TDEC$ in MWH

$$TDEC = TPSR - TPVR \text{ in MWH} \quad 3.2$$

Table. 1. Energy data obtained from Transmission Company of Nigeria (TCN) Irrua Station from October 2018 to September, 2019

| Months | Availability Period(AP) (h) | Previous Reading (MWh) | Present Reading (MWh) | Consumption (MWh) |
|---------------|-----------------------------|------------------------|-----------------------|-------------------|
| October, 18 | 495 | 112574 | 115297 | 2723 |
| November, 18 | 468 | 115297 | 118511 | 3214 |
| December, 18 | 447 | 118511 | 122032 | 3521 |
| January, 19 | 443 | 122032 | 125237 | 3205 |
| February, 19 | 496 | 125237 | 128710 | 3473 |
| March, 19 | 558 | 120710 | 132200 | 3490 |
| April, 19 | 564 | 132200 | 135504 | 3304 |
| May, 19 | 589 | 135504 | 138776 | 3272 |
| June, 19 | 568 | 138776 | 141885 | 3109 |
| July, 19 | 470 | 141885 | 144562 | 2677 |
| August, 19 | 493 | 144562 | 146763 | 2201 |
| September, 19 | 484 | 146763 | 149276 | 2513 |

Table.2. Energy data obtained from Irrua Specialist Teaching Hospital (ISTH) 33/11 kV Station from October 2018 to September 2019.

| Period | ISTH Injection Substations | Availability Period (h) | Previous Reading (MWh) | Present Reading (MWh) | Consumption (MWh) |
|----------------|----------------------------|-------------------------|------------------------|-----------------------|-------------------|
| October, 2018 | Clinical | 495 | 55.853 | 59.054 | 3.201 |
| | Bank PHB | 495 | 147.032 | 148.283 | 1.251 |
| | Doctors Quarters | 495 | 2412.951 | 2450.163 | 37.212 |
| | Otibhor | 495 | 3398.291 | 3450.845 | 52.554 |
| | Labour Ward | 495 | 2.914 | 3.935 | 1.021 |
| | Lassa Fever | 495 | 1.812 | 2.913 | 1.010 |
| | Total | | | | 96.340 |
| November, 2018 | Clinical | 468 | 59.054 | 62.701 | 3.647 |
| | Bank PHB | 468 | 148.283 | 149.697 | 1.414 |
| | Doctors Quarters | 468 | 2450.163 | 2500.315 | 50.152 |
| | Otibhor | 468 | 3450.845 | 3527.644 | 76.799 |
| | Labour Ward | 468 | 3.935 | 8.020 | 4.085 |
| | Lassa Fever | 468 | 2.913 | 3.421 | 0.508 |
| | Total | | | | 136.605 |
| December, 2018 | Clinical | 447 | 62.701 | 66.060 | 3.359 |
| | Bank PHB | 447 | 149.697 | 151.306 | 1.609 |
| | Doctors Quarters | 447 | 2500.315 | 2536.663 | 36.348 |
| | Otibhor | 447 | 3527.644 | 3583.165 | 55.521 |
| | Labour Ward | 447 | 8.020 | 9.605 | 1.585 |
| | Lassa Fever | 447 | 3.421 | 4.530 | 1.109 |
| | Total | | | | 99.231 |
| January, 2019 | Clinical | 443 | 66.060 | 70.699 | 4.639 |
| | Bank PHB | 443 | 151.306 | 153.379 | 2.073 |
| | Doctors Quarters | 443 | 2536.663 | 2574.234 | 37.571 |
| | Otibhor | 443 | 3583.165 | 3644.274 | 61.109 |
| | Labour Ward | 443 | 9.605 | 11.391 | 1.786 |
| | Lassa Fever | 443 | 4.530 | 5.755 | 1.225 |
| | Total | | | | 108.403 |
| February, 2019 | Clinical | 496 | 70.699 | 76.189 | 5.490 |
| | Bank PHB | 496 | 153.379 | 154.301 | 0.922 |
| | Doctors Quarters | 496 | 2574.234 | 2660.513 | 86.279 |
| | Otibhor | 496 | 3644.274 | 3761.756 | 117.482 |
| | Labour Ward | 496 | 11.391 | 12.011 | 0.620 |
| | Lassa Fever | 496 | 3.755 | 6.465 | 0.710 |
| | Total | | | | 211.503 |
| March, 2019 | Clinical | 558 | 76.189 | 79.184 | 2.995 |
| | Bank PHB | 558 | 154.301 | 155.331 | 1.030 |
| | Doctors Quarters | 558 | 2660.513 | 2678.510 | 17.997 |
| | Otibhor | 558 | 3761.756 | 3791.758 | 30.002 |
| | Labour Ward | 558 | 12.011 | 13.084 | 1.073 |
| | Lassa Fever | 558 | 6.465 | 7.048 | 0.583 |
| | Total | | | | 53.680 |

Table 4. Energy data obtained from Benin Electricity Distribution Company 33/11 kV Ekpoma injection station from October, 2018 to September, 2019.

| Period | Ekpoma Injection Substations | Availability Period (h) | Previous Reading (MWh) | Present Reading (MWh) | Consumption (MWh) |
|----------------|------------------------------|-------------------------|------------------------|-----------------------|-------------------|
| October, 2018 | Ekpoma Town | 249 | 53626 | 54320 | 694 |
| | Ujemen | 405 | 15531 | 15592 | 61 |
| | Express Ekpoma | 202 | 37780 | 38272 | 492 |
| | Irrua | 211 | 32393 | 32768 | 375 |
| | Opoji | 219 | 11268 | 11401 | 133 |
| | Total | | | | 1755 |
| November, 2018 | Ekpoma Town | 287 | 54320 | 55225 | 905 |
| | Ujemen | 404 | 15592 | 15678 | 86 |
| | Express Ekpoma | 221 | 38272 | 38879 | 607 |
| | Irrua | 256 | 32768 | 33305 | 537 |
| | Opoji | 252 | 11401 | 11565 | 164 |
| | Total | | | | 2299 |
| December, 2018 | Ekpoma Town | 304 | 55225 | 56192 | 967 |
| | Ujemen | 390 | 15678 | 15782 | 104 |
| | Express Ekpoma | 242 | 38879 | 39507 | 628 |
| | Irrua | 302 | 33305 | 33926 | 621 |

| | | | | | |
|----------------|----------------|-----|--------|-------|-------|
| January, 2019 | Opoji | 297 | 11565 | 11740 | 175 |
| | Total | | | | 2495 |
| | Ekpoma Town | 258 | 56192 | 57047 | 855 |
| | Ujemen | 408 | 15782 | 15848 | 66 |
| | Express Ekpoma | 269 | 393507 | 40258 | 751 |
| | Irrua | 234 | 33926 | 34418 | 492 |
| | Opoji | 231 | 11740 | 11892 | 155 |
| February, 2019 | Total | | | | 2,319 |
| | Ekpoma Town | 253 | 57047 | 57919 | 872 |
| | Ujemen | 408 | 15848 | 15949 | 101 |
| | Express Ekpoma | 209 | 40258 | 40845 | 587 |
| | Irrua | 232 | 34418 | 34866 | 448 |
| | Opoji | 230 | 11895 | 12050 | 155 |
| | Total | | | | 2,163 |
| March, 2019 | Ekpoma Town | 263 | 57919 | 58813 | 894 |
| | Ujemen | 504 | 15949 | 16038 | 89 |
| | Express Ekpoma | 248 | 40845 | 41447 | 602 |
| | Irrua | 221 | 34866 | 35306 | 440 |
| | Opoji | 218 | 12050 | 12197 | 147 |
| | Total | | | | 2,172 |

Table 6. Energy data obtained from BEDC 33/11kV Ambrose Alli University Injection Station from October, 2018 to September, 2019.

| Period | AAU Injection Station Feeder | Availability Period (h) | Previous Reading (MWh) | Present Reading (MWh) | Consumption (MWh) |
|-----------------|------------------------------|-------------------------|------------------------|-----------------------|-------------------|
| October, 2018 | AAU | 403 | 3772 | 3865 | 93 |
| | Iruokpen | 202 | 22318 | 22756 | 438 |
| | Total | | | | 531 |
| November, 2018 | AAU | 412 | 3865 | 3948 | 83 |
| | Iruokpen | 198 | 22756 | 23188 | 432 |
| | Total | | | | 515 |
| December, 2018 | AAU | 390 | 3948 | 3995 | 47 |
| | Iruokpen | 208 | 23188 | 23679 | 491 |
| | Total | | | | 538 |
| January, 2019 | AAU | 352 | 3995 | 4051 | 56 |
| | Iruokpen | 243 | 23679 | 24222 | 543 |
| | Total | | | | 599 |
| February, 2019 | AAU | 439 | 4051 | 4150 | 99 |
| | Iruokpen | 223 | 24222 | 24661 | 439 |
| | Total | | | | 538 |
| March, 2019 | AAU | 520 | 4150 | 4283 | 133 |
| | Iruokpen | 289 | 24661 | 25266 | 605 |
| | Total | | | | 738 |
| April, 2019 | AAU | 521 | 4283 | 4406 | 123 |
| | Iruokpen | 209 | 25266 | 25710 | 444 |
| | Total | | | | 567 |
| May, 2019 | AAU | 492 | 4406 | 4501 | 95 |
| | Iruokpen | 210 | 25710 | 26135 | 425 |
| | Total | | | | 520 |
| June, 2019 | AAU | 483 | 4501 | 4570 | 69 |
| | Iruokpen | 186 | 26135 | 26491 | 356 |
| | Total | | | | 425 |
| July, 2019 | AAU | 403 | 4570 | 4654 | 84 |
| | Iruokpen | 192 | 26491 | 26872 | 381 |
| | Total | | | | 465 |
| August, 2019 | AAU | 462 | 4654 | 4733 | 79 |
| | Iruokpen | 248 | 26872 | 27277 | 405 |
| | Total | | | | 484 |
| September, 2019 | AAU | 402 | 4733 | 4801 | 68 |
| | Iruokpen | 234 | 27277 | 27738 | 461 |
| | Total | | | | 529 |

Table 9. The Voltage and Current on Ehor 33 kV Distribution line for the month of October, 2018 to September, 2019.

| Months | Vpeak(volts) | Ipeak(ampere) |
|--------------|--------------|---------------|
| October, 18 | 33000 | 495 |
| November, 18 | 33000 | 468 |
| December, 18 | 33000 | 447 |

| | | |
|---------------|-------|-----|
| January, 19 | 33000 | 443 |
| February, 19 | 33000 | 496 |
| March, 19 | 33000 | 558 |
| April, 19 | 33000 | 564 |
| May, 19 | 33000 | 589 |
| June, 19 | 33000 | 568 |
| July, 19 | 33000 | 470 |
| August, 19 | 33000 | 493 |
| September, 19 | 33000 | 484 |

IV. Results And Discussion

Results

The total transmitted energy consumed (TTEC) from Transmission Company of Nigeria, Irrua 132/33 kV Station by Benin Electricity Distribution Company and total distributed energy consumed (TDEC) from Benin Electricity Distribution Company by consumers, where obtained and calculated using algorithms.

Data Analysis

Total transmitted energy consumed from the month of October, 2018 to September, 2019 where analyses using algorithm equation, as shown in table 10

Table 10. Total transmitted energy consumed from the month of October, 2018 to September, 2019.

| Months | Previous Reading, PVR (MWh) | Present Reading, PSR (MWh) | Consumption, TTEC (MWh) |
|---------------|-----------------------------|----------------------------|-------------------------|
| October, 18 | 112574 | 115297 | 2723 |
| November, 18 | 115297 | 118511 | 3214 |
| December, 18 | 118511 | 122032 | 3521 |
| January, 19 | 122032 | 125237 | 3205 |
| February, 19 | 125237 | 128710 | 3473 |
| March, 19 | 120710 | 132200 | 3490 |
| April, 19 | 132200 | 135504 | 3304 |
| May, 19 | 135504 | 138776 | 3272 |
| June, 19 | 138776 | 141885 | 3109 |
| July, 19 | 141885 | 144562 | 2677 |
| August, 19 | 144562 | 146763 | 2201 |
| September, 19 | 146763 | 149276 | 2513 |




Fig.4. Transmitted Energy Consumption

Tables (11 – 15) shows the total distributed energy consumed in ISTH (which is represented by I_c), the 33/11 kV Ekpoma injection station (which is represented by E_c), the Ambrose Alli University injection station (which is represented by A_c), and the 33/0.415 kV Ehor direct station (which is represented by D_c), respectively.

Table 11 and Fig.5 shown energy consumption in megawatt hour (MWh) in ISTH 33/11 kV stations from October, 2018 to September, 2019.

Table 11. Energy consumption (MWh) in ISTH 33/11 kV stations from October, 2018 to September, 2019.

| Months | Clinical (MWh) | Bank PHB (MWh) | Doctors Quarters (MWh) | Otabor (MWh) | Labour ward (MWh) | Lassa Fever (MWh) | Total Consumption (MWh) |
|---------------|----------------|----------------|------------------------|--------------|-------------------|-------------------|-------------------------|
| October, 18 | 3.201 | 1.251 | 37.212 | 52.554 | 1.021 | 1.010 | 96.340 |
| November, 18 | 3.647 | 1.414 | 50.152 | 76.799 | 4.085 | 0.508 | 136.605 |
| December, 18 | 3.359 | 1.609 | 36.348 | 55.521 | 1.585 | 1.109 | 99.231 |
| January, 19 | 4.639 | 2.073 | 37.571 | 61.109 | 1.786 | 1.225 | 108.403 |
| February, 19 | 5.490 | 0.922 | 86.279 | 117.482 | 0.620 | 0.710 | 211.503 |
| March, 19 | 2.995 | 1.030 | 17.997 | 30.002 | 1.073 | 0.583 | 53.680 |
| April, 19 | 0.072 | 0.300 | 39.426 | 53.038 | 0.684 | 0.710 | 94.230 |
| May, 19 | 2.810 | 0.601 | 29.749 | 51.049 | 0.527 | 0.811 | 85.547 |
| June, 19 | 3.210 | 0.168 | 22.447 | 33.224 | 0.725 | 0.621 | 60.395 |
| July, 19 | 2.011 | 0.236 | 26.123 | 56.789 | 0.652 | 0.523 | 86.334 |
| August, 19 | 1.500 | 0.356 | 21.354 | 61.021 | 0.542 | 0.902 | 85.675 |
| September, 19 | 3.582 | 0.408 | 24.013 | 54.693 | 0.412 | 0.756 | 83.864 |




Fig. 5. Energy consumption in Irrua specialist teaching hospital

Table 12. Energy consumption (MWh) in ISTH 33/11 kV Ekpoma Injection stations from October, 2018 to September, 2019.

| Months | Ekpoma Town (MWh) | Ujemen (MWh) | Express Ekpoma (MWh) | Irrua (MWh) | Opoji (MWh) | Total Consumption (MWh) |
|---------------|-------------------|--------------|----------------------|-------------|-------------|-------------------------|
| October, 18 | 694 | 61 | 492 | 375 | 133 | 1755 |
| November, 18 | 905 | 86 | 607 | 537 | 164 | 2299 |
| December, 18 | 967 | 104 | 628 | 621 | 175 | 2495 |
| January, 19 | 855 | 66 | 751 | 492 | 155 | 2319 |
| February, 19 | 872 | 101 | 587 | 448 | 155 | 2163 |
| March, 19 | 894 | 89 | 602 | 440 | 147 | 2172 |
| April, 19 | 808 | 95 | 648 | 467 | 147 | 2165 |
| May, 19 | 611 | 87 | 444 | 341 | 115 | 1598 |
| June, 19 | 515 | 68 | 453 | 392 | 137 | 1565 |
| July, 19 | 750 | 81 | 530 | 470 | 192 | 2023 |
| August, 19 | 459 | 64 | 326 | 269 | 110 | 1228 |
| September, 19 | 741 | 85 | 421 | 341 | 103 | 1691 |




Fig. 6: Energy consumption in Ekpoma 33/11 kV injection station

Table 13. Energy consumption analysis in megawatt hour (MWh) of all the feeders in Ambrose Alli university (AAU) 33/11 kV injection station from October, 2018 to September, 2019.

| Months | AAU (MWh) | Irukep (MWh) | Total (MWh) |
|---------------|-----------|--------------|-------------|
| October, 18 | 93 | 438 | 531 |
| November, 18 | 83 | 432 | 515 |
| December, 18 | 47 | 491 | 538 |
| January, 19 | 56 | 543 | 599 |
| February, 19 | 99 | 439 | 538 |
| March, 19 | 133 | 605 | 738 |
| April, 19 | 123 | 444 | 567 |
| May, 19 | 95 | 425 | 520 |
| June, 19 | 69 | 356 | 425 |
| July, 19 | 84 | 381 | 465 |
| August, 19 | 79 | 405 | 484 |
| September, 19 | 68 | 461 | 529 |




Fig. 7: Energy consumption in AAU injection station

Table 14: Energy consumption in megawatt hour of all 33/0.415 kV direct Ehor substations from October, 2018 to September, 2019.

| Months | Aiko Hotel (MWh) | Ugbiyuya (MWh) | Okemum Ehor (MWh) | Arosa Ehor | Market Ehor (MWh) | Upohi Ehor (MWh) | Watch Tower (MWh) | Total (MWh) |
|---------------|------------------|----------------|-------------------|------------|-------------------|------------------|-------------------|-------------|
| October, 18 | 1.010 | 0.284 | 0.201 | 2.239 | 3.011 | 1.211 | 25.850 | 33.836 |
| November, 18 | 1.121 | 0.341 | 0.251 | 2.141 | 3.214 | 1.120 | 42.780 | 50.968 |
| December, 18 | 0.960 | 0.322 | 0.305 | 1.984 | 2.981 | 1.058 | 221.050 | 228.660 |
| January, 19 | 1.271 | 0.405 | 0.281 | 2.654 | 2.842 | 1.358 | 118.000 | 126.811 |
| February, 19 | 1.126 | 0.289 | 0.255 | 2.418 | 3.141 | 1.253 | 195.810 | 204.292 |
| March, 19 | 1.024 | 0.354 | 0.241 | 1.876 | 3.052 | 1.098 | 100.130 | 107.775 |
| April, 19 | 1.131 | 0.309 | 0.408 | 2.102 | 2.168 | 1.128 | 24.810 | 33.056 |
| May, 19 | 1.041 | 0.311 | 0.389 | 2.241 | 2.749 | 1.257 | 35.200 | 43.188 |
| June, 19 | 1.204 | 0.365 | 0.352 | 2.012 | 3.451 | 1.284 | 57.820 | 66.488 |
| July, 19 | 1.108 | 0.389 | 0.325 | 2.118 | 3.127 | 1.222 | 14.840 | 23.129 |
| August, 19 | 1.212 | 0.411 | 0.256 | 2.315 | 3.502 | 1.985 | 29.280 | 38.961 |
| September, 19 | 1.132 | 0.387 | 0.351 | 2.041 | 3.110 | 1.204 | 38.750 | 46.975 |




Fig. 8: Energy consumption on direct Ehor 33kV line.

Table 15: The total distributed energy obtained from BEDCPlc.

| Months | Ic (MWh) | Ec (MWh) | Ac (MWh) | Dc (MWh) | TDEC (MWh) |
|---------------|----------|----------|----------|----------|------------|
| October, 18 | 96.340 | 175.000 | 531.000 | 33.836 | 2416.176 |
| November, 18 | 136.605 | 2299.000 | 515.000 | 50.968 | 3001.573 |
| December, 18 | 99.231 | 2495.000 | 538.000 | 228.660 | 3360.891 |
| January, 19 | 108.403 | 2319.000 | 599.000 | 126.811 | 3153.214 |
| February, 19 | 211.503 | 2163.000 | 538.000 | 204.292 | 3116.795 |
| March, 19 | 53.680 | 2172.000 | 738.000 | 107.775 | 3071.455 |
| April, 19 | 94.230 | 2165.000 | 567.000 | 33.056 | 2859.286 |
| May, 19 | 85.547 | 1598.000 | 520.000 | 43.188 | 2246.735 |
| June, 19 | 60.345 | 1565.000 | 425.000 | 66.488 | 2116.833 |
| July, 19 | 86.334 | 2023.000 | 465.000 | 23.129 | 2597.463 |
| August, 19 | 85.675 | 1228.000 | 484.000 | 38.961 | 1836.636 |
| September, 19 | 83.864 | 1691.000 | 529.000 | 46.975 | 2350.803 |




Fig. 9: The total distributed energy consumed on Ehor 33 kV line

Table 16: The difference between total transmitted energy consumed and total distributed energy consumed (MWh) from transmission company and distribution company.

| Months | TTEC (MWh) | TDEC (MWh) | EEL (MWh) |
|---------------|------------|------------|-----------|
| October, 18 | 2723.000 | 2416.176 | 306.824 |
| November, 18 | 3214.000 | 3001.573 | 212.427 |
| December, 18 | 3521.000 | 3360.891 | 160.109 |
| January, 19 | 3205.000 | 3153.214 | 51.786 |
| February, 19 | 3473.000 | 3116.795 | 356.205 |
| March, 19 | 3490.000 | 3071.455 | 418.545 |
| April, 19 | 3304.000 | 2859.286 | 444.714 |
| May, 19 | 3272.000 | 2246.735 | 1025.265 |
| June, 19 | 3109.000 | 2116.833 | 992.167 |
| July, 19 | 2677.000 | 2597.463 | 79.537 |
| August, 19 | 2201.000 | 1836.636 | 364.364 |
| September, 19 | 2513.000 | 2350.803 | 162.197 |




Fig. 10: The difference between total transmitted energy consumed and total distributed energy consumed (MWh) from transmission company and distribution company.

Table 17: The difference between total transmitted energy consumed and total distributed energy consumed (kWh) from transmission company and distribution company.

| Months | TTEC(kWh) | TDEC (kWh) | EEL(kWh) |
|---------------|------------|------------|----------|
| October, 18 | 2,723,000 | 2,416,176 | 30682 |
| November, 18 | 3214,000 | 3001573 | 212427 |
| December, 18 | 3521,000 | 3360891 | 160109 |
| January, 19 | 3205,000 | 3153214 | 51786 |
| February, 19 | 3473,000 | 3116795 | 356205 |
| March, 19 | 3490,000 | 3071455 | 418545 |
| April, 19 | 3304000 | 2859286 | 444714 |
| May, 19 | 3272,000 | 2246735 | 1025265 |
| June, 19 | 3109000 | 2116833 | 992167 |
| July, 19 | 2677000 | 2597463 | 79537 |
| August, 19 | 2201000 | 1836636 | 364364 |
| September, 19 | 2513000 | 2350803 | 162197 |
| Total | 36,702,000 | | |




Fig. 12: The difference between total transmitted energy consumed and total distributed energy consumed (kWh) from transmission company and distribution company.

Table 18: The total voltage, current and apparent power on Ehor33kV distribution line from the month of October, 2018 to September, 2019.

| Months | Vpeak (volts) | Ipeak (ampere) | Vrms (volts) | Irms (ampere) | TAP (Vrms)(Irms) |
|---------------|---------------|----------------|--------------|---------------|------------------|
| October, 18 | 33000 | 495 | 23334.52 | 350.02 | 8167548.69 |
| November, 18 | 33000 | 468 | 23334.52 | 330.93 | 7722092.70 |
| December, 18 | 33000 | 447 | 23334.52 | 316.08 | 7375575.08 |
| January, 19 | 33000 | 443 | 23334.52 | 313.25 | 7309538.39 |
| February, 19 | 33000 | 496 | 23334.52 | 350.72 | 8183882.85 |
| March, 19 | 33000 | 558 | 23334.52 | 394.57 | 9207101.56 |
| April, 19 | 33000 | 564 | 23334.52 | 398.81 | 9306039.92 |
| May, 19 | 33000 | 589 | 23334.52 | 416.49 | 9718594.24 |
| June, 19 | 33000 | 568 | 23334.52 | 401.64 | 9372076.61 |
| July, 19 | 33000 | 470 | 23334.52 | 332.34 | 7754994.38 |
| August, 19 | 33000 | 493 | 23334.52 | 348.60 | 8134413.67 |
| September, 19 | 33000 | 484 | 23334.52 | 342.24 | 7986006.13 |

Table 19: The total availability period, total transmitted energy consumed in kWh, kW, W and total apparent power (VA) on Ehor 33 kV distribution line.

| Months | AP (h) | TTEC (kWh) | TTEC (kW) | TTEC (W) | TAP (VA) |
|--------------|--------|------------|-----------|----------|----------|
| October, 18 | 495 | 2723000 | 5501.010 | 5501010 | 81675499 |
| November, 18 | 468 | 3214000 | 6867.521 | 6867521 | 7722093 |
| December, 18 | 447 | 3521000 | 7876.957 | 7876957 | 7375575 |

| | | | | | |
|---------------|-----|---------|----------|----------|-----------|
| January, 19 | 443 | 3205000 | 7234.763 | 7234763 | 7309538 |
| February, 19 | 496 | 3473000 | 7002.763 | 7002016 | 8183883 |
| March, 19 | 558 | 349000 | 6254.480 | 6254480 | 9207102 |
| April, 19 | 564 | 3304000 | 5858.156 | 5858156 | 9306040 |
| May, 19 | 589 | 3272000 | 5555.178 | 5555178 | 9718594 |
| June, 19 | 568 | 3109000 | 5473.592 | 5473592 | 9372077 |
| July, 19 | 470 | 2677000 | 5695.744 | 5695744 | 7754994 |
| August, 19 | 493 | 2201000 | 4464.503 | 4464503 | 8134414 |
| September, 19 | 484 | 2513000 | 5192.149 | 5192149 | 7986006 |
| Total | | | | 72976069 | 166027865 |




Fig. 11: Total Transmitted Energy Consumed and Total Apparent Power

Table 20: The difference between TTEC, TDEC (kWh), tariff classification and RL on Ehor 33 kV distribution line.

| Months | TTEC (kWh) | TDEC (kWh) | EEL (kWh) | TARIFF R2S | RL (N) |
|---------------|------------|------------|-----------|------------|---------------|
| October, 18 | 2,723,000 | 2,416,176 | 30,682 | 31.26 | 959,119.32 |
| November, 18 | 3,214,000 | 3,001,573 | 212,427 | 31.26 | 6,640,468.02 |
| December, 18 | 3,521,000 | 3,360,891 | 160,109 | 31.26 | 5,005,007.34 |
| January, 19 | 3,205,000 | 3,153,214 | 51,786 | 31.26 | 1,618,830.36 |
| February, 19 | 3,473,000 | 3,116,795 | 356,205 | 31.26 | 11,134,968.30 |
| March, 19 | 3,490,000 | 3,071,455 | 418,545 | 31.26 | 13,083,716.70 |
| April, 19 | 3,304,000 | 2,859,286 | 444,714 | 31.26 | 13,901,759.64 |
| May, 19 | 3,272,000 | 2,246,735 | 1,025,265 | 31.26 | 32,049,783.90 |
| June, 19 | 3,109,000 | 2,116,833 | 992,167 | 31.26 | 31,015,140.42 |
| July, 19 | 2,677,000 | 2,597,463 | 79,537 | 31.26 | 2,486,326.62 |
| August, 19 | 2,201,000 | 1,836,636 | 364,364 | 31.26 | 11,390,018.64 |
| September, 19 | 2,513,000 | 2,350,803 | 162,197 | 31.26 | 5,070,278.22 |




Fig. 12: Revenue Losses in Distribution Company

V. Conclusion

Conclusion

Finding a solution to the issue of electric energy loss at Benin electricity distribution company Plc network has been successfully attempted, using Ehor 33 kV distribution line as a sample. Analysis of data obtained from both the transmission company of Nigeria Irrua station and Benin Electricity Distribution Company Plc, where used to identify the losses on Ehor 33 kV distribution line. It was discovered that the increase in availability brings about increase in energy losses. It is clear that, if capacitor banks are installed close to transformers which are the source of supply to consumers, the power factor will reduce to approximately unity. This suggests that the flow of reactive power will be at its lowest level. Also, the inspection method carried out along Ehor 33 kV distribution line shows that 65% of the distribution line are covered with light vegetation along the line, almost 70% of the porcelain insulations are piloted on concrete poles with broken cross-arm tied to the pole, sag wires along the line and different rating of conductors were used in constructing Ehor 33 kV distribution line. Also, the rate of revenue lost on the side of the distribution company is high, which affect the company cost of purchasing energy from market operators.

References

- [1]. Suquo, E., & Archibong, E. (2021). Comparative Analysis Of Electrical Power Losses In Distribution Network. *International Journal Of Engineering Research And Technology*, 10(2), 196-204.
- [2]. Chang, C., Jiang, W., & Huan, L. (2021). Study On Differential Energy Saving And Loss Reduction Countermeasures For Medium Voltage And Low Voltage Distribution Network. *Power Capacitor*, 41(5), 164–170.
- [3]. Christescu, C., Radoi, R., & Dumitrescu, C. (2017). Experimental Research On Energy Losses Through Friction. *IOP Conference Series: Materials Science And Engineering*, 174(1), Article 012011.
- [4]. Council Of European Energy Regulators. (2020). Report On Power Losses (Ref: C19-EQS-101-03). <https://www.ceer.eu>
- [5]. Dagare, B., Baseem, K., & Hassan, H. A. (2021). Distribution Network Reliability Enhancement And Power Loss Reduction By Optimal Network Reconfiguration. *Electrical Engineering*, 96(Part A), Article 107518.
- [6]. Dontus, U., & O'tega, E. (2021). Effect Of Transmission And Distribution Losses On Electricity Supply. *Journal Of Science And Technology*, 2(1), 60–68.
- [7]. Eduardo, A. P., & Gustavo, A. S. (2021). Non-Technical Losses In An Electrical Distribution System. *Journal Of Electrical And Electronic Systems*, 10(3), 345.
- [8]. Emmanuel, M. E., Matthew, O. O., Emeka, S. E., Gafar, T., & Farouq, E. S. (2021). Non-Technical Loss Detection And Mitigation System For Power Distribution Networks. *European Journal Of Engineering And Technology Research*, 6(5), 120–125.
- [9]. Enobakhare, G., & Oyonokpare, E. (2020). Reliability Assessment Of Electric Power Distribution: A Case Study Of 2×7.5 Mega Volt Ampere, 33 Kilo Volt/11 Kilo Volt Etete Injection Sub-Station, Nigeria. *International Journal Of Engineering Science And Application*, 9(2), 55–65. <https://dergipark.org.tr/en/pub/ijesa/issue/93081/1577756>
- [10]. Eric, E. N. (2022). Evaluation Of Electric Power Losses On The 33/11 Kv Distribution Feeder Network. *European Journal Of Electrical Engineering And Computer Science*, 6(6), 1–8.
- [11]. Gomen, V. (2019). Analysis Of Power Loss Reduction In Smart Grids. In 2019 International Russian Automation Conference (Rusautocon) (Pp. 563–570). IEEE.
- [12]. Hamidi, N., Darestabu, S. A., & Farshchian, S. (2021). Distribution Network In Iran Electrical System. *Iranian Journal Of Energy*, 14(2), 45-59.
- [13]. Hassan, H. A., Anteneh, D., Baseen, K., & Mahala, P. (2021). Distribution Network Reliability And Power Loss Reduction. *Computers And Electrical Engineering*, 96(Part A), Article 107518.
- [14]. Hussein, H. A. (2011). Evaluation Of Power Losses [Unpublished Manuscript]. College Of Technology, Iraq.
- [15]. Ismail, M., Hassan, E. M., & Tijani, L. (2020). Distribution Network Reconfiguration Of Power Loss Minimization. In *2020 Global Congress On Electrical Engineering (GC-Eleceng)* (Pp. 45-50). IEEE.
- [16]. Komolafe, O. M., & Udofia, K. M. (2020). Power Loss Minimization In Distribution Network. *Journal Of Engineering Research*, 39(1), 246–254.
- [17]. Matthew, S., Hope, O., Olaitan, A., & Anuta, E. (2020). Loss In Nigeria Distribution System. *International Journal Of Engineering Research And Technology*, 13(11), 3251–3254.
- [18]. Mohammed, H. (2018). A Proposed Management Concept For Power Losses In Electric Networks. *American Journal Of Engineering And Applied Sciences*, 11(2), 92–113.